



FIRE FIGHTER I

JPR: FFI-5A

Candidate: _____

STANDARD: 4.5.1 NFPA 1001, 2019 Edition Preparedness, and Maintenance	Task: Clean and check ladders, ventilation equipment, SCBA, ropes, salvage equipment, and hand tools, given cleaning tools, cleaning supplies, and an assignment, so that equipment is clean and maintained according to manufacturer's or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise.	
PERFORMANCE OUTCOME:	The candidate shall demonstrate the ability to select correct tools for various parts and pieces of equipment, follow guidelines, and complete recording and reporting procedures. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.	
Equipment Required: Ladders, rope, salvage equipment, ventilation equipment, hand tools, SCBA, service tags, and cleaning supplies.		
CONDITIONS: Given firefighting equipment, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
EQUIPMENT TO BE CLEANED AND INSPECTED (SCBA Mandatory & Check One Other):		
SCBA <input type="checkbox"/>	Hand Tool <input type="checkbox"/>	Ventilation Equipment <input type="checkbox"/>
Ladder <input type="checkbox"/>	Rope <input type="checkbox"/>	Salvage Equipment <input type="checkbox"/>
SCBA		
1.	Inspect / Clean face piece according to department policies.	
2.	Inspect / Clean back plate/frame/harness assembly according to department policies.	
3.	Inspect / Clean cylinder.	
4.	Place in ready state or report any deficiencies.	
Hand Tools		
<i>Wooden / Fiberglass Handles:</i>		
1.	Inspect Handle.	
2.	Inspect Head / Cutting edge / Surface.	
3.	Clean Tool.	
4.	Place in ready state or report any deficiencies.	

No.	Task Steps	✓
Ventilation Equipment - PICK ONE		
Fueled		
1.	Check fuel level.	
2.	Check that appropriate guards are in place.	
3.	Check starting.	
4.	Place in ready state and report any deficiencies.	
Electric		
1.	Check electric cords for damage if applicable.	
2.	Check that appropriate guards are in place.	
3.	Check starting.	
4.	Place in ready state and report any deficiencies.	
Ladders		
1.	Clean Ladder.	
2.	Examine all beams, guides, halyard, cable, pawls, pulleys, rails, rungs, bolts, rivets, welds, heat indicator, and movable parts.	
3.	Place in ready state and report any deficiencies.	
Rope		
1.	Clean rope.	
2.	Visually and physically inspect rope for damage.	
3.	Place in ready state and report any deficiencies.	
Salvage Equipment		
1.	Clean provided salvage equipment.	
2.	Inspect equipment and identify damage.	
3.	Place in ready state and report any deficiencies.	

Evaluator (Print & Sign)

Date:



FIRE FIGHTER I

JPR: FFI-5B

Candidate: _____

STANDARD: 4.5.2 NFPA 1001, 2019 Edition Preparedness, and Maintenance	Task: Clean, inspect, and return fire hose to service, given washing equipment, water, detergent, tools, and replacement gaskets, so that damage is noted and corrected, the hose is clean, and the equipment is placed in a ready state for service.	
PERFORMANCE OUTCOME:	The candidate shall demonstrate the ability to clean different types of hose, operate hose washing and drying equipment (if available), mark defective hose, and replace coupling gaskets, roll hose, and reload hose. Safety: A safety violation is grounds for automatic failure. All proctors present shall review the safety violation.	
Equipment Required: Fire apparatus, scrub brush, hose, cleaning supplies, replacement gaskets, hose washer and dryer (if available), log book or tags for reporting repair needs, and personal protective clothing (proctor to determine what PPE is to be worn).		
CONDITIONS: Given Fire Department hose and apparatus, the candidate shall demonstrate the ability to:		
No.	Task Steps	✓
INSPECT / CLEAN HOSE		
1.	Inspect / Clean hose.	
2.	Inspect / Clean couplings according to department guidelines.	
3.	Dry hose.	
4.	Place in ready state and report any deficiencies.	
RETURNING HOSE TO SERVICE		
5.	Roll hose as selected by proctor (Check one):	
	Straight <input type="checkbox"/> Donut <input type="checkbox"/> Twin Donut <input type="checkbox"/> Self-Locking Twin Donut <input type="checkbox"/>	
6.	Reload hose on apparatus using a hose load specific to apparatus or department:	
	Pre-connect	
	Supply Line	

Evaluator (Print & Sign)

Date: